



1. SEE DRAWINGS E9.21.52 AND E9.21.53 FOR LIGHTING  
PANEL SCHEDULES.

2. SEE DRAWINGS E9.30.01 AND E9.30.02 FOR FIXTURE  
SCHEDULES.

<b>NO01</b>	ALL NORMAL LIGHTING FIXTURES ON THIS DRAWING ARE CIRCUITED FROM PANEL 2L3A LOCATED IN ELECTRICAL ROOM 2-3-123.
<b>NO02</b>	ALL EMERGENCY LIGHTING FIXTURES AND EXIT SIGNS ON THIS DRAWING ARE CIRCUITED FROM PANEL B1E1A LOCATED IN ELECTRICAL ROOM 81-2-31. LIGHTING IN STAIR NO. 1 TO BE CIRCUITED FROM PANEL B1E1A IN ELECTRICAL ROOM 81-2-31.
<b>NO03</b>	ALL FIXTURES ARE MOUNTED 9'-5" A.F.F. UNLESS OTHERWISE NOTED.
<b>NO04</b>	CORRIDOR FIXTURES (W1) ARE MOUNTED 8'-0" A.F.F.



108031400-E8E-8600-A200



Knight/Jacobs Joint Venture  
701 Scarboro Road, MS 8253  
Oak Ridge, TN 37830  
865-241-9433  
fax 865-241-3400

**KNIGHT**  
Knight Advanced Technology




Oak Ridge National Laboratory  
managed for the DEPARTMENT OF ENERGY under  
U.S. GOVERNMENT contract DE-AC05-00OR22725  
JIT-DATRIE 11C, 2 Oak Ridge, Tennessee

PROJECT NAME:  
SPALLATION NEUTRON SOURCE  
CENTRAL LAB AND OFFICE BUILDING  
ELECTRICAL LIGHTING PLAN  
LEVEL 02, SECTOR 62 - ALTERNATE #1D

1 3	48 E	49 X	50 X	PLANT 8	BLDG 8600	FL	SH. 1	OF 1	TYPE P	CLASS U
51 NC	52 NA	53	WBS 1.8.3.14 E3.02.62.A1						REV 0	


NO REPRESENTATION OR WARRANTY, EXPRESSED OR IMPLIED, IS MADE AS TO THE ACCURACY, COMPLETENESS OR TRUTHFULNESS OF THE INFORMATION OR STATEMENTS CONTAINED IN THESE DRAWINGS, OR THAT THE USE OR DISCLOSURE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS MAY NOT INFRINGE PRIVATE RIGHTS OF OTHERS. NO LIABILITY IS ASSUMED WITH RESPECT TO THE USE OF, OR FOR DAMAGES RESULTING FROM THE USE OF ANY INFORMATION, APPARATUS, METHOD, OR PROCESS DISCLOSED IN THESE DRAWINGS. DRAWINGS MADE AVAILABLE FOR INFORMATION TO BIDDER ARE TO BE USED ONLY FOR THE PURPOSES AND ARE TO BE RETURNED UPON REQUEST OF THE FORMING DRAWING CONTRACTOR.

NUMBER OF—  
SECTION OR  
DETAIL

SECTION AND DETAIL KEY

THIS DOCUMENT  
CONTROLLED BY

CHANGE CONTROL  
SYSTEM 4

ENGINEERING  
PROCEDURE SNS-ENG-G001[illegible]

DSN	T. WHITE	12/20/01
DRW	T. WHITE	12/20/01
CHK	K.SZOT	12/20/01
DEPT		
PE	<i>[Signature]</i>	12/27/01
PJ	<i>[Signature]</i>	12/26/01
REQ		
UTE	<i>[Signature]</i>	12/26/01

ING APPROVALS